



No	DATE	REVISION DETAILS
05	070907 P.J.W	MINIMUM CONTROL SIGNAL DURATION WAS 1 SECOND CHANGED FOR IQPRO MAIN PCB WAKE UP TIME. CHECKED M.H

www.rotork.com

ROTORK CONTROLS LTD BATH, BA1 3JQ ENGLAND Tel: 01225-733200	ROTORK CONTROLS INC ROCHESTER NY 14624, USA Tel: 585-328-1550
--	--

CONFIG BY PJW
 DATE 021003
 CHECKED MH
 BASE WD 3002-400
 JOB No -
 M.I.No -

IQ DC + MODBUS MODULE.

CIRCUIT DIAGRAM No -REV 102
3002-400-05

B1 C1 B2 C2